AD Enclosure - MI-3

Search and Secure Procedure

MI-3
MI3.V1.1

1) "A" and "B" resets Box #1
2) "A" and "B" sweep the tunnel to Box #2. If the Mini-Loop is good, reset Box #2 and continue. Else, "A" holds while "B" checks the tunnel to reset Box #2A.
3) "A" and "B" sweep the tunnel to Box #3. If the Mini-Loop is good, reset Box #3 and continue. Else, "A" holds while "B" checks the tunnel to reset Box #3A.
4) "A" and "B" sweep the tunnel to Box #4. If the Mini-Loop is good, reset Box #4 and continue. Else, "A" holds while "B" checks the tunnel to reset Box #4A.
5) "B" holds while "A" resets Box #5 on the way to reset Box #6.
6) "A" and "B" sweep the tunnel to Box #7. If the Mini-Loop is good, reset Box #7 and continue. Else, "A" holds while "B" checks the tunnel to reset Box #7A.
7) "B" holds while "A" goes to reset Box #8. If the Dump is dropped, it will need to secured. Proceed to Page 2.
8) "A" and "B" sweep the tunnel to Box #9. If the Mini-Loop is good, reset Box #9 and continue. Else, "A" holds while "B" checks the tunnel to reset Box #9A.
9) "A" and "B" sweep the tunnel to Box #10. If the Mini-Loop is good, reset Box #10 and continue. Else, "A" holds while "B" checks the tunnel to reset Box #10A.
10) "B" holds while "A" resets Box #11.
11) "A" joins "B", together they reset Box #12 and Box #13.



Reviewed AD/RSO	Date
Gary Lauten	1-30-13
Approved AD/OPS Dept. Head	Date
Daniel Johnson	2/5/13

CONTROLLED DOCUMENT
Users are responsible for ensuring they work to the latest approved revision. Printed or electronically transmitted copies are uncontrolled.

AD Enclosure - MI-40 Dump

Search and Secure Procedure

MI-40 Dump

MI3.V1.0



1. "**A**" holds in tunnel, "**B**" proceeds to the Dump Room.
2. If the Dump Room is secured, "**B**" resets Interlock Box #8 and joins "**A**". If not continue with steps 3 through 7.

3. "**B**" checks for anyone in the forward area of the room.
4. "**B**" uses the mirror to check for anyone on top of absorber block.
5. "**B**" proceeds around absorber block to Interlock box #8A. making sure screens, covering bottom of block, are locked.
6. "**B**" Looks down the walkway to gate. Resets Interlock box #8A, proceeds to exit door resetting Interlock box #8
7. Rejoin "**A**" and resume tunnel search and secure.

Reviewed AD/RSO	Date
[signature]	1-30-13
Approved AD/OPS Dept. Head	Date
[signature]	2/5/13

CONTROLLED DOCUMENT
Users are responsible for ensuring they work to the latest approved revision. Printed or electronically transmitted copies are uncontrolled.